

Download Mxl Fire Alarm Panel Manual

SERVICE MXL Control Panel n Advanced fire protection control panel z Multiplexed Alarm Reporting z Custom Site Specific Custom Programming n Basic Panel Contains: z Two Addressable Loop z Two NAC Circuits z Three System Relays (Alarm, Trouble, Supervisory) n Additional MOM-4 Motherboard z Additional System Modules, Input or Control Outputs with the MXL Panel through a serial communications system. All modules are continuously supervised for their presence and for proper operation. Problems are shown on the display to aid in servicing and troubleshooting. The MXL System is designed so that fire alarm operation has first priority over all other modes of operation. If the System Manual acknowledge function at the fire alarm control unit shall silence the audible trouble alarm; visual alarm shall continue to be displayed and notification to the LBNL MXL receiving station (Building 48) via the MXL network (loop) shall be maintained until initiating device failure or circuit trouble is cleared. MXL-IQ Control Panel pdf manual download. ... Inform the person in charge of the MXL-IQ Walktest. fire alarm system that a Walktest is to be performed and that part or all of the fire detection system will be disabled. Page 107: Walktest The System • Press ENTER, or wait 60 seconds and Alarm causing devices in Walktest do NOT the MXL-IQ ...